

SECTION TABLE OF CONTENTS

DIVISION 09 - FINISHES

SECTION 09651J

RESILENT WALL BASE

02/05

PART 1 GENERAL

- 1.1 SUBMITTALS
- 1.2 COLOR AND PATTERNS

PART 2 PRODUCTS

- 2.1 RECOMMENDED MANUFACTURER'S
- 2.2 VINYL WALL BASE
- 2.3 RUBBER WALL BASE
- 2.4 ADHESIVE
- 2.5 STAIR TREAD/RISERS
- 2.6 PORCELAIN PAVER TILES/BASE

PART 3 EXECUTION

- 3.1 GENERAL
- 3.2 APPLICATION

-- End of Section Table of Contents --

SPACE GATEWAY SUPPORT (SGS) SGS 09651J (February 2005)

SECTION 09651J

RESILENT WALL BASE
02/05

NOTE: This guide specification covers the
requirements for Resilient Wall Base and Resilient
Stair Treads.

PART 1 GENERAL

1.1 SUBMITTALS

NOTE: Review submittal description (SD) definitions
in Section 01300, "Submittals," and edit the
following list to reflect only the submittals
required for the project. Submittals should be kept
to the minimum required for adequate quality
control. Include a columnar list of appropriate
products and tests beneath each submittal
description.

The following shall be submitted in accordance with Section 01330,
"Submittals," in sufficient detail to show full compliance with the
specification:

SD-03 Product Data

Manufacturer's Product Data and installation instructions as well
as maintenance instructions.

SD-04 Samples

Samples of type, color and pattern of wall base.

1.2 COLOR AND PATTERNS

As shown or scheduled on drawings. Submit samples of each product type,
color and pattern for review and approval.

PART 2 PRODUCTS

2.1 RECOMMENDED MANUFACTURER'S

Armstrong World Industries, Inc.
American Floor Products Co. Inc.
Endura Rubber Flooring
Crossfield Products, Inc.

2.2 VINYL WALL BASE

Fed. Spec. SS-W-40A, Notice 1(7 Jun 74), Type II; 4 inches high, 0.080 inch gauge; with matching end stops and preformed corner units; standard top-set cove. Provide three copies of Product Data.

2.3 RUBBER WALL BASE

Fed. Spec. SS-W-40A, Notice 1(7 June 74), Type II; 4 inches high, 1/8 inch gauge; with matching end stops and preformed corner units; standard top-set cove.

2.4 ADHESIVE

As recommended by the manufacturer.

2.5 STAIR TREAD/RISERS

Provide resilient stair treads as manufactured by the following:

DAP, Inc.
Burke Flooring Products
Advanced Polymer Technology Corporation

2.6 PORCELAIN PAVER TILES/BASE

Provide ceramic tiles in 4" x 4" and other sizes as manufactured by the following:

Interceramic, USA
American Olean
DATILE

PART 3 EXECUTION

3.1 GENERAL

Prior to installation, ensure that surfaces are clean, thoroughly dry, smooth, firm and sound and free from springiness, oil, paint, wax, dirt or any other damaging material.

3.2 APPLICATION

Provide wall base as specified herein. Apply wall base in accordance with the installation instructions. Perform work by personnel thoroughly experienced in the application of such flooring.

Adhesives: Apply adhesives in accordance with the adhesive manufacturer's printed directions, unless specified or directed otherwise. Smoking, the use of open flames, and other immediate sources of ignition are strictly prohibited in the area where adhesives are being used or spread. Post conspicuous signs regarding NO SMOKING OR OPEN FLAME in the area where adhesives are being spread.

Wall base: Apply wall base after installation of wallcovering has been completed and the wall surface to which the base is to be applied is thoroughly dry. Apply special base adhesive to the back of the base with a notched trowel, leaving approximately 1/4 inch bare space along the top edge of the base. Immediately press the base firmly against the wall and

move gently into place, making sure that the toe is in contact with the floor surface and the wall. Roll the entire surface of the base with a hand roller and press the toe of the base firmly against the wall with a straight piece of wood. Clean after installation.

Fill cracks and voids in the wall with a crack filler as specified for this application. Bring irregular surfaces to a smooth finish with a smoothing compound.

Cleaning: Immediately upon completion of the installation in a room or area, dry-clean wall base surfaces with a cleaner to remove surplus adhesive. Provide three copies of manufacturer's maintenance instructions.

Finishing: Clean bases but do not polish.

-- End of Section --